

Personnel Interlock systems



Andreas Rathjen
Personnel Interlock
DESY MPS

Hamburg, June 2025
HELMHOLTZ



Personnel Interlock Systems


Implementation of risk assessment requirements, especially for applications with a high safety level (SIL3 safety integrity level)

Introduction

- Risk assessment: identification of risks, estimation of the risks
- Hardware design of a suitable Functional Safety
- evaluation of the measure
- Fail-safe Software development
- Hard- and Software Code Review
- commissioning with functional test
- system acceptance
- acceptance of changes


Risk Assessment

identification of risks




Best practice –
make it inherently safe!

Risk Assessment Standards



If inherent safety is not possible, the design of functional safety and an assessment of the residual risk is mandatory

ISO 12100 Safety of machinery – General principles for design – Risk assessment and risk reduction



Process of risk reduction

ISO 13849 Safety of machinery – Safety related parts of control systems

Performance Level a,b,c,d,e

PL

IEC/EN 62061 "Safety of machinery: Functional safety of electrical, electronic and programmable electronic control systems"

Safety Integrity Level 1,2,3

SIL

application of harmonized standards can ensure compliance with legal requirements

Risk Assessment


Relation between
Performance Level and
Safety Integrity Level

| <u>ISO 13849</u> | Probability of a dangerous Failure per Hour (PFHd) | <u>IEC/EN 62061</u> |
|------------------|--|---------------------|
| PL | a $\geq 10^{-5}$ bis $< 10^{-4}$ | - |
| | b $\geq 3 \times 10^{-6}$ bis $< 10^{-5}$ | 1 |
| | c $\geq 10^{-6}$ bis $< 3 \times 10^{-6}$ | 1 |
| | d $\geq 10^{-7}$ bis $< 10^{-6}$ | 2 |
| | e $\geq 10^{-8}$ bis $< 10^{-7}$ | 3 |
| | | SIL |

Risk Assessment

Estimation of the risks

Risk Graph




Standard ISO 13849 Safety of machinery – Safety related parts of control systems

Design of a suitable Functional Safety

two channel safety architecture


Example for Performance Level e – Solution in accordance with standard ISO13849



crosscheck and diagnostic – architecture: safety category 4

Failsafe PLC with input/output - interface

Door safety switch




Power contactor



with EDM- External Device Monitoring (force guided contacts)

Diagnostic



Design of a suitable Functional Safety

Function test for detecting fault accumulations and undetected faults

New requirement in
the standard:
Diagnostic coverage
interval at least
monthly for PLe

In a redundant system, an accumulation of faults over time could lead to a loss of the safety function.

To avoid undetected faults, safety circuits with **non-electronic technology** must be triggered regularly.

If a functional test is required to detect a possible accumulation of faults or an undetected fault before the next request, it must be performed within the following test intervals:


At least monthly for PLe (SIL3)

At least every 12 months for PLd (SIL2)

Design of a suitable Functional Safety

→ Monthly testing is often not practicable (e.g. open a interlock door between the regular maintenance)

non-electronic devices



- Power contactors
- Mechanical switches
- Safety relay
- Key switch

Quote from the manual: Siemens-SIRIUS 3SK1 Safety Relay

! WARNING

3SK1..1 and 3SK1..3 safety relays (devices with contacting outputs):

In continuous operation, the key safety values apply where the function test interval (state change of the outputs) for SIL2 ≤ 1 year and for SIL3 ≤ 1 month.

Example key exchange system (DOLD)

| Safety Related Data | | | | |
|--|-------------|-------------|-------------|-------------|
| Data suitable for the PFHd summation method according to EN ISO13849-1: 2016 | | | | |
| Category | 2 | 3 | 3 | 4 |
| PL | d | d | e | e |
| PFH _d | 2.12199E-09 | 1.36918E-09 | 1.08914E-09 | 1.50183E-10 |
| Diagnostics Coverage ratio DC | 60 % | 60 % | 90 % | 99 % |
| Test interval | 1 / year | 1 / year | 1 / month | 1 / month |

Design of a suitable Functional Safety

OSSD - „Output Switching Signal Device

This electronic switch detect short-circuits and cross-circuits up to PLe in accordance with EN ISO 13849

Faults also detected in the actuated state via electronic diagnostics



Switch with a “high” diagnostic coverage (DC)
This device avoid a monthly testing by rare safety requests in case of a PLe application

Classical safety switch




An electro-mechanical switch fulfills at most PLd according to the standard ISO13849



OSSD - „Output Switching Signal Device

Two OSSD outputs are switched off with a time delay. During the pause time of the output, a built-in input is activated and read back.


Example for: OSSD - „Output Switching Signal Device



OSSD - „Output Switching Signal Device

If 24 V is present at the input after the output is switched off, an error is detected by the sensor and the OSSD outputs switch off safely.

Example for: OSSD - „Output Switching Signal Device



correct feedback-signal is missing:

- sensor switches both outputs immediately
- sensor generates error message

Evaluation of the measure

The PFHd (Probability of a dangerous failure by hour) value can be calculated manually or with a software tool (e.g. Sistema).

Therefore is the technical data of the safety components necessary.

The PFHd must be compared with the requirement of the risk assessment.

If the required Performance Level (PLr) is not reached, the design must be improved.

Evaluation Tool SISTEMA

Data input:

- technical data (B10d-, MTTFd-,...)
- safety architecture
- diagnostic coverage
- ...




The screenshot shows the SISTEMA software interface for evaluating safety functions. The main window displays a safety function diagram with various components and their associated performance levels (P1, P2) and failure modes (F1, F2). The interface includes a menu bar, a toolbar, and a sidebar with project navigation. The central panel shows the required Performance Level (PLr) and the resulting Performance Level (PL) and PFHD value.

| Modulatorfreigabe | |
|-------------------|--------|
| PLr | d |
| PL | e |
| PFHD [1/h] | 1,6E-8 |



Fail-safe Software development




The PLC hardware must be created in accordance with the safety specification

PLC Hardware



The screenshot shows the Siemens SIMATIC Manager interface for configuring a PLC rack. The rack is labeled 'GenericRack_ET20...' and contains 16 slots. Slot 0 is occupied by a SIMATIC ET 200 station. Slots 1-5 contain SIMATIC ET 200 modules. Slots 6-15 contain SIMATIC ET 200 modules. The 'F_DI_1_Extract [F-DI 8x24VDC HF]' configuration window is open, showing the 'Allgemein' tab. The 'Kanalparameter' section is expanded to show 'Kanal 0, 4' and 'Kanal 0'. The 'Auswertung der Geber' is set to '1oo1 (1v1)-Auswertung'. The 'Diskrepanzverhalten' is set to '0-Wert bereitstellen'. The 'Diskrepanzzeit' is set to 5 ms. The 'Wiedereingliederung nach Diskrepanzfehler' is set to 'Test 0-Signal nicht erforderlich'. The 'Kanal 0' section shows 'Aktiviert' checked, 'Kanalfehler Quittierung' set to 'Manuell', 'Geberversorgung' set to 'Geberversorgung 0', 'Eingangsverzögerung' set to 3,2, 'Anzahl Signalwechsel' set to 5, and 'Überwachungsfenster' set to 2 sec.

Fail-safe Software development

PLC Software




The PLC software must be created in accordance with the safety specification




Software Documentation

Siemens - programming tool TIA




Print a safety summary by using the programming tool

Paper print



Hard- and Software Code-Review

Verification



Testing the Safety-Specification against the PLC-Software

Code review

Key questions to clarify:


Is the function complete realized?

Is the logic correct?


Are the software (time-) parameters suitable?

PLC Software

Netzwerk 1: Preconditions for BeamPermission_FLASH_0_1_EXTR




Netzwerk 2: BeamPermission_FLASH_0_1_EXTR




Hard- and Software Code-Review

Verification



PLC Hardware



F_DI_1_Extract [F-DI 8x24VDC HF]

Allgemein | IO-Variablen | Systemkonstanten | Texte

► Allgemein
 ► Potenzialgruppe
 ► Baugruppenparameter
 F-Parameter
 ▼ DI-Parameter
 ► Geberversorgung
 ▼ Kanalparameter
 ▼ Kanal 0, 4
 Kanal 0
 Kanal 4
 ► Kanal 1, 5
 ► Kanal 2, 6
 ► Kanal 3, 7
 E/A-Adressen

Kanalparameter

> Kanal 0, 4

Auswertung der Geber: 1oo1 (1v1)-Auswertung
 Diskrepanzverhalten: 0-Wert bereitstellen
 Diskrepanzzeit: 5 ms
 Wiedereingliederung nach Diskrepanzfehler: Test 0-Signal nicht erforderlich

> > Kanal 0

Aktiviert
 Kanalfehler Quittierung: Manuell
 Geberversorgung: Geberversorgung 0
 Eingangsverzögerung: 3,2
 Anzahl Signalwechsel: 5
 Überwachungsfenster: 2 sec

| F-DQ 4x24VDC/2A PM HF_3 : ET2005P_Schaltschrank, Steckplatz 6 | |
|---|-------------------------------|
| Allgemeine Parameter | Spezifische Parameter |
| Hardware | Maximale Testzeit |
| Name | F-DQ 4x24VDC/2A PM HF_3 |
| Steckplatz | Kanal 0 |
| Kurzbezeichnung | Aktiviert |
| Artikel-Nr. | Max. Rücklezeit Dunkeltest |
| 6E57 136-6D800-0CA0 | 1,0 ms |
| Anfangsadresse Eingang | Max. Rücklezeit Einschalttest |
| 30 | 0,6 ms |
| Anfangsadresse Ausgang | Helitest aktiviert |
| 30 | ja |
| HW-Kennung | Diagnose: Drahtbruch |
| 285 | ja |
| F-Überwachungszeit | Kanal 1 |
| 150 ms | Aktiviert |
| F-Quelleadresse | ja |
| 100 | Max. Rücklezeit Dunkeltest |
| F-Zieladresse | 1,0 ms |
| 65527 | Max. Rücklezeit Einschalttest |
| F-Parameter-Signatur (ohne Adresse) | 0,6 ms |
| 0x1D9B (7579) | Helitest aktiviert |
| F-Parameter-Signatur (mit Adresse) | ja |
| 0x806E (45166) | Diagnose: Drahtbruch |
| Verhalten nach Kanalfehler | ja |
| Passivieren des Kanals | Kanal 2 |
| Nein | Aktiviert |
| RIOforFA-Safety | Nein |
| V2-mode | Max. Rücklezeit Dunkeltest |
| Loop-back extension (LP) | 1,0 ms |
| Firmware-Version | Max. Rücklezeit Einschalttest |
| V1.0 | 0,6 ms |
| Software | Helitest aktiviert |
| F-Peripherie-DB-Nummer | Nein |
| B0018 | Diagnose: Drahtbruch |
| F-Peripherie-DB-Name | Aktiviert |
| F00030_F-DQ4x24VDC/2APMHF_3 | Nein |
| Verwendet in F-Ablaufgruppe | Max. Rücklezeit Dunkeltest |
| ALG1 | 1,0 ms |
| | Max. Rücklezeit Einschalttest |
| | 0,6 ms |
| | Helitest aktiviert |
| | Nein |
| | Diagnose: Drahtbruch |
| | Nein |

Testing the Safety-Specification against the PLC-Hardware

Code review

Key questions to clarify:

Is the Hardware correctly designed (electrical data)?

Is the Hardware correctly configured (addresses)?

Are the Hardware parameters suitable (time-, wire-... monitoring)?

commissioning with functional test

A comprehensive checklist must be created according to the I/O list and the safety specifications.

Check that the documentation of the safety-devices, the hard-and software fits together.

Start commissioning.

- I/O-test - check Input- and Output signals and the related devices
- Check the Hardware parameters and configuration by manual triggered faults (e.g. discrepancy fault)
- Push sensors and switches and check the correct reaction

Use the possibility's of your development equipment:

Tags of the safety program can be monitored at any time

Checklist

| Prüfung | Ereignis / Tätigkeit | erwartete Reaktion | OK ✓ / Bemerkung |
|-------------------|---|---|------------------|
| Absuche | | | |
| Absuche Extract | Absuche starten - Not-Aus drücken | Abbruch Absuche | |
| | Absuche starten bei betätigten NotAus | keine Reaktion (Störmeldung liegt vor) | |
| | Absuche Start über BK2 | Abschurdurchgabe Extract startet, Leuchtmelder am OS ① | ✓ |
| | Tür Extraction setzen | keine Reaktion | |
| | Quitterschloss betätigen | Leuchtmelder am OS ② - LM Extraction ST ① | |
| | Tür Extraction setzen | keine Reaktion | |
| | Suchhebel Extraction drücken | LM Extraction ST ② - LM Setzschloss ExrTür ① | |
| | Tür Extraction öffnen halten und setzen | keine Reaktion | |
| | Tür Extraction schließen und setzen | LM Extraction Schliessschalter ③ - TW1 ① | |
| | gestiftetes Türverriegelock über HMI auflösen | Abschurdurchgabe Extract ④ HMI Geleitetstatus "abgesucht" | |
| | Erneut absuchen und Extract Tür öffnen | HMI Geleitetstatus getrocknen "TW1 aus" | |
| | | TI Extract getrocknen - TW1 ⑤ Fehlermeldung | |
| Absuche Flash-2-3 | Absuche starten - Not-Aus drücken | Abbruch Absuche | |
| | Absuche starten bei betätigten NotAus | keine Reaktion (Störmeldung liegt vor) | |
| | Absuche Start über BK2 | Abschurdurchgabe Flash-2-3 startet, LM Setzhebel Dump2 ① | |
| | Tür Seed2 schließen und setzen | keine Reaktion | |
| | Suchhebel Dump2 drücken | keine Reaktion | |
| | Tür Dump2 öffnen und setzen | keine Reaktion | |

The checklist must be completed without any errors detected, otherwise you have to fix the problem and start again from “the beginning”

System acceptance

Independent expert

As a general rule, the acceptance of a Failsafe-System is performed by an independent expert. The independence required of the expert must be defined in the safety plan and depends on the required PL/SIL.

| Degrees of independence IEC61508 | SIL1 (PLc) | SIL2 (PLd) | SIL3 (PLe) |
|----------------------------------|-------------|------------------------------|------------------------------|
| independent person | recommended | recommended | not sufficient |
| independent department | | recommended (new technology) | recommended |
| independent organization | | | recommended (new technology) |

System acceptance

If all these steps have been carried out, an independent expert must be consulted now at the latest

Verification & Validation

Completeness and correctness of the safety program including hardware configuration (including testing)
Completeness and correctness of the safety equipment

Function test

In practice: check the whole functional safety and confirm that it works

Documentation


Completeness and correctness of the risk assessment, safety summary, circuit diagram, safety evaluation

Version check


Once you have checked all properties of the offline safety program you must ensure that the safety program is identical on the F-CPU on which it is supposed to be run.
Check the installation – Are the intended devices installed?

System acceptance

Version Check




PLC – display



Summary (paper print)


The safety summary signature must be the same which is shown in the PLC!

(PLC-display or check the referred safety data block online)



System acceptance

Check the actually installed equipment



circuit diagram with equipment list



The documented and evaluated devices must be installed and no other!

| | | | | |
|--------------------|---|---|--------------------|-----|
| 6ES7526-2BF00-0AB0 | 1 | ET 200MP, F-DQ 8x24VDC 2A PPM | 6ES7526-2BF00-0AB0 | SIE |
| 6ES7521-1BH10-0AA0 | 3 | S7-1500, DI 16x24VDC BA | 6ES7521-1BH10-0AA0 | SIE |
| 6ES7522-1BH10-0AA0 | 2 | S7-1500, DQ 16x24VDC/0.5A BA | 6ES7522-1BH10-0AA0 | SIE |
| 3SK1111-1AB30 | 3 | SIRIUS SICHERHEITSSCHALTGERAET STD R3+1 | 3SK1111-1AB30 | SIE |

System acceptance

Validation & Verification



Documentation



Function test



Version check



Functional safety fully audited




Acceptance of changes

Impact analysis

Acceptance of Changes

In general, you can adopt the same approach for the acceptance of changes as the initial Acceptance

Check the entire safety-related project data for changes and determine the safety-related project data to be validated and approved as part of an impact analysis.




Annual testing

Annual testing:

Create a checklist with the following topics and work through it

- Check Software-Signature: must be unchanged
- Check wires and components: must be undamaged, clean and dry
- Check the whole effect chain of all safety functions: Everything works like expected

| Checklist | | | |
|--|--|--|------------------|
| Prüfung | Ereignis / Tätigkeit | erwartete Reaktion | OK ✓ / Bemerkung |
| Absuche | | | |
| Absuche Extract | Absuche starten - Not-Aus drücken | Abbruch Absuche | ✓ |
| | Absuche starten bei beängstigtem Notaus | keine Reaktion (Störmeldung liegt vor) | |
| | Absuche Start über BKR | Absuchdurchfrage Extract startet, Leuchtmelder am OS ① | |
| | Tür Extraction setzen | keine Reaktion | |
| | Quitterschloss betätigen | Leuchtmelder am OS ① - LM Extraction ST ① | |
| | Tür Extraction setzen | keine Reaktion | |
| | Suchtaster Extraction drücken | LM Extraction ST ① - LM Setzschloss für Tür ① | |
| | Tür Extraction öffnen halten und setzen | keine Reaktion | |
| | Tür Extraction schließen und setzen | LM Extraction Schlüsselhalter ① - TW1 ① | |
| | gesetztes Türeninterlock über HMI aufheben | Absuchdurchfrage Extract ① HMI Gebietsstatus "abgesucht" | |
| erneut absuchen und Extract Tür öffnen | HMI Gebietsstatus gebrochen, TW1 aus T1 Extract gebrochen - TW1 ① Fehlermeldung | | |
| Absuche Flash-2-3 | | | |
| Absuche Flash-2-3 | Absuche starten - Not-Aus drücken | Abbruch Absuche | |
| | Absuche starten bei beängstigtem Notaus | keine Reaktion (Störmeldung liegt vor) | |
| | Absuche Start über BKR | Absuchdurchfrage Flash-2-3 startet, LM Setzaster Dump2 ① | |
| | Tür Flash2 schließen und setzen | keine Reaktion | |
| | Suchtaste Dump2 drücken | keine Reaktion | |



If the signature remains unchanged, the PLC software and hardware parameters do not need to be checked again.

The logic must be the same, but does everything work as it should?

Conclusion

- First, clarify whether an independent expert is helpful or even necessary
- Risks must be identified and assessed at the start of the project
- The application of harmonized standards can ensure compliance with legal requirements
- The use of standard solutions and certified components makes development and testing easier
- A suitable design with appropriate devices can reduce the interim manual checks using diagnostics
- A well thought-out implementation of functional safety saves time and money over the entire life cycle

Thank you for your attention!

Contact

Deutsches Elektronen-
Synchrotron DESY

www.desy.de

Andreas Rathjen
Notkestraße 85
D-22607 Hamburg
Dept. DESY-MPS
andreas.rathjen@desy.de
+49 40 8998 2528